




綺利人造石

透光雲石(雪花石) 透光木紋石 透光鳳凰石 透光玉石
透光類真石 透光真石板 檯面人造石

綺利透光石板系列產品
採取 CNS 7614 防焰一級測試
採取 CNS 14535 防焰一級測試
通過 CNS7614 A法 防焰一級測試

SGS

材料工程實驗室-台北

試驗報告

報告編號: HB-11-02065X
C-11-06186
頁數: 1 OF 1
報告日期: 100年04月15日

委託單位: 綺利國際有限公司
樣品名稱: 透光人造雲石
送驗人員: 綺利國際有限公司(李星)
收件日期: 100年04月01日
試驗日期: 100年04月11日~100年04月13日
備註: 以上資料由顧客提供(收件及試驗日期除外)

試驗結果:

試驗項目	試驗方法	試驗結果
耐酸性	參考 CNS 2215(2006)	表面無異狀
耐鹼性		表面無異狀
含水率(%)	參考 CNS 3802(2008)	0.3

註: 本試驗之樣品不在 TAF 認可範圍內, 故無法出具 TAF 標誌之報告。



經濟部標準檢驗局 試驗報告

報告號碼: 9A300000355
申請者: 綺利國際有限公司
品名: 人造透光雲石
規格: (空白)
型號: (空白)
受理日期: 100年03月07日

完成日期: 100年05月04日

試驗項目	試驗結果
防焰性	
炭化長度	0 cm
餘焰	0 秒
餘燼	於 1 分鐘後無餘燼
種類	10 秒加熱時間, 防焰為 1 級
燃燒性	
20mm 垂直燃燒試驗	符合 V-0 之規定
試驗說明:	
1. 測試期間: 100年3月7日至100年5月4日	
2. 試驗方法:	
2.1(1)試驗項目: 防焰性參照 CNS 7614 進行試驗	
(2)試驗項目: 燃燒性參照 CNS 14535 進行試驗	
2.2 儀器設備: 防焰性項目 (財產編號: 110-3100906-0028-0000005-003)	
燃燒性項目 (財產編號: 3101103-520-010 3-5243)	
2.3 試驗地點: 10051 臺北市中正區濟南路1段4號	
3. 報告內容如有疑問, 請洽本局: 第六組高分子檢驗科	
聯絡電話: 02-23431876 傳真: 02-23431883	
其它事項或備註:	
1. 防焰性一項, 試樣經 CNS 7614 A 法處理	
樣品資料:	
(以下空白)	

副本

第 2 頁 / 共 3 頁

規範要求僅供參考, 合格之判定以委託單位實際要求為準。







報告簽署人


Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, copied or used without prior written permission of the Company.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and www.sgs.com/terms_and_conditions.htm. Any holder of this document is advised that reproduction without the Company's written permission is prohibited. The Company's liability is limited to the extent of the services provided and any other services provided by the Company. The Company's liability is limited to the extent of the services provided and any other services provided by the Company. The Company's liability is limited to the extent of the services provided and any other services provided by the Company.

SGS Taiwan Ltd. | No. 31, No. 33, No. 35, Wu Chuan Road, Wu Chuan Road, Wu Chuan Road, Taipei, Taiwan / 台北縣五股區五權路31號, 33號, 35號
台灣檢驗科技股份有限公司 | 電話: 886-21-2298-3355 | 傳真: 886-21-2298-3352 | 網址: www.sgs.com


Member of SGS Group





本系列產品係由真石膠合而成，裁切時請建議送至專業石材廠切割。


透光真石板



MK-7006



MK-7018



MK-8021



MK-8022